



Ref. Certif. No.

DE 2-046094

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Grid-Tied PV Inverter

Name and address of the applicant

GoodWe Technologies Co., Ltd.
No.90 Zijin Rd., New District
215011 Suzhou, P.R. China

Name and address of the manufacturer

GoodWe Technologies Co., Ltd.
No.90 Zijin Rd., New District
215011 Suzhou, P.R. China

Name and address of the factory

See additional page(s)

Ratings and principal characteristics

Max. PV Input Voltage: 900V d.c., 1100V d.c.

Trademark (if any)

GOODWE (LOGO)

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

GW150K-GT-G10 , GW100K-GT-L-G10

Additional information (if necessary may also be reported on page 2)

Detail information refer to test report CN26P4BQ 001.

A sample of the product was tested and found to be in conformity with

IEC 62109-2:2011
IEC 62109-1:2010

As shown in the Test Report Ref. No. which forms part of this Certificate

CN26P4BQ 001

This CB Test Certificate is issued by the National Certification Body



TÜVRheinland®

TÜV Rheinland LGA Products GmbH
Tillystr. 2, 90431 Nürnberg, Germany
Phone + 49 221 806-1371
Fax + 49 221 806-3935
Mail: cert-validity@de.tuv.com
Web : www.tuv.com

Date: 2026-01-20

Signature:

A. Chen

1. GoodWe (GuangDe) Power Supply
Technology Co., Ltd.
No. 208, Tong Rui East Road
Guangde
Anhui, P.R. China
2. GoodWe Technologies Co., Ltd.
No.90 Zijin Rd., New District
215011 Suzhou
P.R. China

Additional information (if necessary)

Report Ref. No. : CN26P4BQ 001

Date: 2026-01-20

Signature:



A. Chen